



Certificate of Continued Compliance 242350090/AA/00



Issued 13-01-2025
Expiry date 13-01-2029

Replaces
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: WPIR-CRT Wireless curtain PIR detector
Trademark: Acre Security
Type designation: WPIR-CRT
Hardware / Software: 02 / 0.1.0.7

Placed on the market under the name or trademark of:

Name of the manufacturer: Vanderbilt International (IRL) Ltd.
Address: Clonshaugh Business & Technology Park
City: D17KV84 Dublin
Country: IE

This certificate is granted to:

Name of the certificate holder: Vanderbilt International (IRL) Ltd.
Address: Clonshaugh Business & Technology Park
City: 17 DUBLIN
Country: Republic of Ireland

Ron Scheepers
Managing director

This certificate has THREE Annexes.

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: C

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

CROW Electronic Engineering Ltd

1 Hansger Street

Afula

Israel

Product inspection location:

CROW Electronic Engineering Ltd

1 Hansger Street

Afula

Israel

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- ANPI asbl: LAB/BIS/REC/1545- 2/25, 19 August 2024
- Hermon Laboratories Ltd.: CRORAD_EN.53606_EN 50131-5-3.doc, 07 August 2024
- Hermon Laboratories Ltd.: CROEMC_EN.53606.doc, 03 July 2024
- Hermon Laboratories Ltd.: CROENV_53606.2.doc, 18 August 2024
- Hermon Laboratories Ltd.: CROIAS_EN 50131-2-2.53606, 04 December 2024
- Hermon Laboratories Ltd.: CROAS_EN 50131-6.53606, 04 December 2024

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-2

December, 2021

Applied Standards

EN 50130-5	June, 2011
EN 50130-4+A1	October, 2014
EN 50131-6+A1	June, 2021
EN 50131-5-3	March, 2017
EN 50131-1+A1+A2+A3	June, 2020

The product as described in this certificate includes the following type designations

- | | |
|------------------------|--|
| - Product description: | WPIR-CRT Wireless curtain PIR detector |
| - Trademark: | Acre Security |
| - Type designation: | WPIR-CRT |
| - Hardware version: | 02 |
| - Software version: | 0.1.0.7 |