



Certificate of
Conformity
202340041/AA/00



Issued 14-05-2024
Expiry date 14-05-2027

Replaces
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 2 registration including yearly product inspection.

Product description: QD-200-AM Anti-Masking Detector
Trademark: QD-200-AM
Type designation: QD-200-AM
Hardware / Software: P0098-EB-02-03.00 / 1.00

Placed on the market under the name or trademark of:

Name of the manufacturer: Orisec Ltd
Address: 1 Saint Crispin Way
City: BB4 4PW Haslingden Lancashire
Country: GB

This certificate is granted to:

Name of the certificate holder: Orisec Ltd
Address: 1 Saint Crispin Way
City: BB4 4PW Haslingden Lancashire
Country: GB

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

This certificate has THREE Annexes.



Remarks and observations

The following conditions are applicable:

Security grade: 3

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

Product inspection location:

SmartSD BV

Minervum 7118

Breda

Netherlands

Documentation lodged for this Certificate of Conformity

Test Reports:

- Kiwa Nederland B.V.: 200700396-001-Ver. 1.00, 02 April 2024

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-2	December, 2021
--------------	----------------

Applied Standards

EN 50130-5	June, 2011
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2+A3	June, 2020

The product as described in this certificate includes the following type designations

- | | |
|------------------------|---------------------------------|
| - Product description: | QD-200-AM Anti-Masking Detector |
| - Trademark: | QD-200-AM |
| - Type designation: | QD-200-AM |
| - Hardware version: | P0098-EB-02-03.00 |
| - Software version: | 1.00 |