



Certificate of Conformity 202340025/AA/01



Issued 14-05-2025
Expiry date 29-05-2027

Replaces 202340025/AA/00
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 2 registration including yearly product inspection.

Product description: CP-60 Control Panel
Trademark: CP-60
Type designation: CP-60
Hardware / Software: P0061-EB-07-08.06 / 6.XX
Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: Orisec Ltd
Address: 1 Saint Crispin Way
City: BB4 4PW Haslingden Lancashire
Country: GB

This certificate is granted to:

Name of the certificate holder: Orisec Ltd
Address: 1 Saint Crispin Way
City: BB4 4PW Haslingden Lancashire
Country: GB

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

This certificate has THREE Annexes.



Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: A

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.

Electromagnetic emission and safety aspects are not covered by this certificate.

Product inspection location:

SmartSD BV

Minervum 7118

Breda

Netherlands

Documentation lodged for this Certificate of Conformity

Test Reports:

- Kiwa Nederland B.V.: 200700833-001-Ver 1.00, 15 May 2024
- Kiwa Nederland B.V.: 200700833-002-Ver 1.00, 03 May 2024
- Kiwa Nederland B.V.: 200700833-ENV-Ver 2.00, 29 May 2024

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-3	March, 2009
------------	-------------

Applied Standards

EN 50130-5	June, 2011
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2+A3	June, 2020
EN 50131-6+A1	June, 2021

The product as described in this certificate includes the following type designations

- Product description: CP-60 Control Panel
 - Trademark: CP-60
 - Type designation: CP-60
 - Hardware version: P0061-EB-07-08.06
 - Software version: 6.XX
-
- Product description: CP-20 Control Panel
 - Trademark: CP-20
 - Type designation: CP-20
 - Hardware version: P0061-EB-07-08.06
 - Software version: 6.XX