

## Certificate of constancy of performance,

**0832-CPR-F1923**

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9<sup>th</sup> March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **Sonos DC Sounders**

*(For full product details and conditions of use refer to appendix)*

Produced by or for

#### **Texecom Ltd**

**Bradwood Court  
St Crispin Way  
Haslingden  
Lancashire  
BB4 4PW  
United Kingdom**

and produced in the manufacturing plant(s)

#### **Texecom Ltd**

**Bradwood Court  
St Crispin Way  
Haslingden  
Lancashire  
BB4 4PW  
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

### **EN 54-3:2001 + A1:2002 + A2:2006 - Sounders**

under system 1 are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on 26 January 2017 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



P Halligan, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 26 January 2017  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

## Appendix to Certificate of constancy of performance 0832-CPR-F1923

### Variants:

|          |                                       |
|----------|---------------------------------------|
| PSS-0084 | Sonos DC Sounder Wide Voltage (Red)   |
| PSS-0089 | Sonos DC Sounder Wide Voltage (White) |
| PSS-0151 | Sonos DC Sounder Wide Voltage (Grey)  |

### Bases:

|          |                         |
|----------|-------------------------|
| PSO-0001 | Shallow base (red)      |
| PSO-0006 | Shallow base (white)    |
| PSO-0003 | Deep base (red)         |
| PSO-0007 | Deep base (white)       |
| PSO-0022 | Sonos Grey Shallow Base |

### Notes:

1. PSS-0084 and PSS-0089 are approved to Type A when used with the shallow base & Type B when used with the deep base only
2. PSS-0151 is approved to Type A Indoor with base PSO-0022 only.
3. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13



P Halligan, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 26 January 2017  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).