

Declaration of Performance.

0832-CPR-F1923

Product Type	PSS-0084; PSS-0089		
Type	Sounder Conventional– Red/White		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0832		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPR-F1923		
Declared Performance			
Essential Characteristics	EN54-3 Subclause	Type A	Type B
Reproducibility	5.2	Pass	Pass
Operational performance	5.3	Pass	Pass
Durability	5.4	Pass	Pass
Dry Heat (operational)	5.5	Pass	Pass
Dry Heat (endurance)	5.6	Pass	Pass
Cold (operational)	5.7	Pass	Pass
Damp heat, cyclic (operational)	5.8	Pass	Pass
Damp heat, steady state (endurance)	5.9	Pass	Pass
Damp Heat, cyclic (endurance) (Only for deep base version)	5.10	N/A	Pass
SO2 corrosion (endurance)	5.11	Pass	Pass
Shock (operational)	5.12	Pass	Pass
Impact (operational)	5.13	Pass	Pass
Vibration (operational)	5.14	Pass	Pass
Vibration (endurance)	5.15	Pass	Pass
Electrostatic discharge (operational)	5.16	Pass	Pass
Radiated electromagnetic fields (operational)	5.16	Pass	Pass
Voltage transients, fast transient bursts (operational)	5.16	Pass	Pass
Enclosure Protection	5.17	Pass	Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: Hugh Devereux Function: Head of Approvals and Compliance

Signature:

Place and date if issue: