



DICHIARAZIONE DI CONFORMITA' CE

N. 1402001

Noi, **INIM ELECTRONICS S.R.L.**,**Via Fosso Antico snc - Fraz. Centobuchi - 63076 Monteprandone (AP) - ITALY**

dichiariamo sotto la nostra esclusiva responsabilità, che i prodotti:

Serie: **ING7 (Industrial)**Modello(i): **ING7zzy-xx**

dove le lettere "zz", "y" ed "xx" sono sostituite dalle stringhe riportate qui di seguito

Descrizione: **Rivelatore gas in contenitore IP55 per uso industriale**

zz	Tipo di gas	y (*)	Elemento sensibile	xx (*)	Interfaccia
00	Metano	S, C	S = Semiconduttore C = Catalitico H = Cella Elettrochimica	OC, 42, RL, AS-C, AS-M, LE, LV	OC = con 2 uscite open-collector per Preallarme e Allarme
01	Gas speciali				
02	Vapori di benzina				
03	Monossido di carbonio	S, H			42 = con uscita analogica 4-20mA
04	Idrogeno	S, C			RL = con 3 uscite a relè con Preallarme, Allarme e Guasto
05	GPL				
06	Propano				
07	Ammoniaca 100/200 ppm	S			AS-C = con uscita ad assorbimento per centrali convenzionali
08	Ammoniaca 1000/2000 ppm				
09	Acetilene	S, C			AS-M = con uscita ad assorbimento per moduli ingresso serie ENEA
10	Ossigeno (eccesso)	H			LE = per loop analogico con protocollo ENEA
11	Ossigeno (difetto)				LV = per loop analogico con protocollo Argus VEGA

(*) i caratteri separati dalla virgola sono alternative possibili

ai quali si riferisce la presente dichiarazione, sono conformi ai requisiti essenziali ed alle altre disposizioni pertinenti stabiliti dalla Direttiva 2004/108/CE (EMCD)

Tali prodotti sono conformi alle seguenti norme e/o ad altri documenti normativi:

EN 61000-6-3:2007 + A1:2011**EN 50270:2006**

La documentazione tecnica è conservata da INIM ELECTRONICS S.R.L.

Monteprandone, 03/02/2014

firma:



Baldovino Ruggieri
(Amministratore Delegato)



EC DECLARATION OF CONFORMITY

No. 1402001

We, **INIM ELECTRONICS S.R.L.**,

Via Fosso Antico snc - Fraz. Centobuchi - 63076 Monteprandone (AP) - ITALY

hereby declare under our sole responsibility, that the products:

Series: **ING7 (Industrial)**

Model(s): **ING7zzy-xx**

where letters "zz", "y" ed "xx" are replaced by strings listed here below

Description: **Gas detector in IP55 box for industrial use**

zz	Gas type	y (*)	Sensing element	xx (*)	Interface
00	Methane	S, C	S = Semiconductor C = Catalytic H = Electrochemical cell	OC, 42, RL, AS-C, AS-M, LE, LV	OC = with 2 open-collector outputs for Pre-alarm and Alarm
01	Special gases				
02	Gasoline vapours				
03	Carbon monoxide	S, H			42 = with 4-20mA analogue output
04	Hydrogen	S, C			RL = with 3 relay outputs for Pre-alarm, Alarm e Fault
05	LPG				
06	Propane				
07	Ammonia 100/200 ppm	S			AS-C = with absorbing output for conventional control panels
08	Ammonia 1000/2000 ppm				
09	Acetylene	S, C			AS-M = with absorbing output for Enea series input modules
10	Oxygen (excess)	H			LE = for analogue loop with ENEA protocol
11	Oxygen (defect)				LV = for analogue loop with Argus' protocol VEGA

(*) characters separated by commas are possible alternatives.

to which this declaration relates, are in conformity with the essential requirements and other relevant requirements of the Directive 2004/108/EC (EMCD)

These products are in conformity with the following standards and/or other normative documents:

EN 61000-6-3:2007 + A1:2011

EN 50270:2006

The technical file is kept by INIM ELECTRONICS S.R.L.

Monteprandone, 03/02/2014

signature:



Baldovino Ruggieri
(Managing Director)